

VOC Content Test Certificate

Thursday 9th October 2025

Supplier: Ssangkom Pty Ltd (Unit 7 & 8, 225A Brisbane Road, BIGGERA WATERS, QLD 4216, Australia).

Product Name: Sealsum Screed - Pre-Blended screed

Date Tested: 08th October 2025 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-05 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia.

Test Data:

Specification Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B	Sealsum Screed Pre-Blended screed
General Purpose Adhesives and Sealants Limit: 50 grams per litre	1 grams per litre as VOC content per material
<i>We hereby certify Sealsum Screed - Pre-Blended screed is below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia</i>	

Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

Dr. Tuan Duong
PhD, BE (Chemical Engineer)
Senior Consultant

Travis Hale
BSc (Biotechnology)
Senior Consultant